





## **Model Number**

## VDM28-8-L-IO/115b/136

Distance sensor

with 300 mm fixed cable and 4-pin, M12 x 1 connector

### **Features**


- Distance measurement using object
- Measuring method PRT (Pulse Ranging Technology)
- · Accurate, clear, and reproducible measuring results
- Minimal black-white difference
- Red laser as the light emitter
- Version with IO-Link interface
- Version with laser class 2

# **Product information**


The VDM28 distance measurement device employs Pulse Ranging Technology (PRT). It has a repeat accuracy of 5 mm with an operating range of 0.2 ... 8 m and an absolute accuracy of 25 mm.

The compact housing of the Series 28 photoelectric sensors, with dimensions of 88 mm (height), 26 mm (width) and 54 mm (depth), make it the smallest device available in its class.

## **Dimensions**



## **Electrical connection**




- O = Light on
- = Dark on

### **Pinout**



1 2 3 4	BN WH BU BK	(brown (white) (blue) (black)
4	br	(black)

# Indicators/operating means



1	Operating display	green
2	Signal display	yellow
3	TEACH-IN button	
4	Mode rotary switch	
5	Laser output	

#### **Technical data** General specifications Measurement range 0.2 ... 8 m Kodak white (90%) Reference target Light source laser diode typ. service life 85,000 h at Ta = +25 °C Light type modulated visible red light Laser nominal ratings LASER LIGHT, DO NOT STARE INTO BEAM Note Laser class Wave length 660 nm Beam divergence 1 mrad Pulse length 5 ns Repetition rate 250 kHz max. pulse energy < 4 n.l Angle deviation max. ± 2° Pulse Ranging Technology (PRT) Measuring method Diameter of the light spot < 10 mm at a distance of 8 m at 20 °C Ambient light limit 50000 Lux Temperature influence typ. ≤ 0.25 mm/K Functional safety related parameters $MTTF_d$ 200 a 10 a Mission Time (T<sub>M</sub>) Diagnostic Coverage (DC) 0 % Indicators/operating means Operation indicator LED green 2 LEDs yellow for switching state Function indicator Teach-In indicator Teach-In: LED green/yellow equiphase flashing; 2.5 Hz Teach Error:LED green/yellow non equiphase flashing; 8.0 Hz Control elements 5-step rotary switch for operating modes selection (threshold setting and operating modes) Switch for setting the threshold values Control elements **Electrical specifications** Operating voltage 10 ... 30 V DC / when operating in IO-Link mode: 18 ... 30 V Ripple 10 % within the supply tolerance No-load supply current $\leq$ 70 mA / 24 V DC I۵ Time delay before availability 1.5 sInterface Interface type IO-Link Protocol IO-Link V1.0 Cycle time min. 2.3 ms COM 2 (38.4 kBaud) Mode Process data witdh 16 bit SIO mode support yes Output Signal output 2 push-pull (4 in 1) outputs, short-circuit protected, reverse polarity protected Switching voltage max. 30 V DC max. 100 mA Switching current Switching frequency 50 Hz 10 ms Response time Measurement accuracy Absolute accuracy ± 25 mm Repeat accuracy < 5 mm **Ambient conditions** Ambient temperature -30 ... 50 °C (-22 ... 122 °F) Storage temperature -30 ... 70 °C (-22 ... 158 °F) **Mechanical specifications** Housing width 25.8 mm Housing height 88 mm Housing depth 54.6 mm Degree of protection Connection 300 mm fixed cable with M12 x 1, 4-pin connector Material Housing Plastic ABS Optical face Plastic pane Mass 90 g Compliance with standards and directives Standard conformity Product standard EN 60947-5-2 IEC 60825-1:2007 Complies with 21 CFR 1040.10 and 1040.11 Laser class except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007

#### Laserlabel

LASER LIGHT
DO NOT STARE INTO BEAM
CLASS 2 LASER PRODUCT
WAVELENGTH: 660 nm
MAX PULSE ENERGY: < 4 nJ
PULSE DURATION: 5 ns
IEC 60825-1: 2007 CERTIFIED.
COMPULES WITH 21 CFR 1040.10
AND 1040.11 EXCEPT FOR DEVIATIONS PURSUANT TO LASER NOTICE
NO. 50, DATED JUNE 24, 2007.

LUMIÈRE LASER
NE PAS REGARDER LE FAISCEAU
PRODUIT LASER CLASSE 2
LONGUEUR D'ONDE: 660 nm
MAX. ÉNERGIE D'IMPULSION: < 4 n.J
DURÉE D'IMPULSION: 5 n.
CERTIFIÉ CEI 60826-1: 2007.
CONFORME AUX NORMES 21 CFR
1040.1 10 ET 1040.1 1 A L'EXCEPTION
DES ÉCARTS CONFORMÉMENT
À LA NOTICE DU LASER
N° 50, DATÉE DU 24 JUIN 2007.

#### **Accessories**

# PACTware 4.1

FDT Framework

### VDM28 IODD

IODD for communication with VDM28-IO-Link sensors

### VDM28-IO-Link DTM

Device DTM for communication with VDM28-IO-Link sensors

### IO-Link-Master02-USB

IO-Link master, supply via USB port or separate power supply, LED indicators, M12 plug for sensor connection

#### **IO-Link-Master-USB DTM**

Communication DTM for use of IO-Link-Master

### **IODD Interpreter DTM**

Software for the integration of IODDs in a frame application (e. g. PACTware)

#### **OMH-05**

Mounting aid for round steel  $\emptyset$  12 mm or sheet 1.5 mm ... 3 mm

### OMH-07-01

Mounting aid for round steel ø 12 mm or sheet 1.5 mm ... 3 mm

## OMH-21

Mounting bracket

#### **OMH-22**

Mounting bracket

# OMH-VDM28-01

Metal enclosure for inserting protective panes or apertures

# **OMH-VDM28-02**

Mounting and fine adjustment device for sensors from the 28 series

### OMH-RLK29-HW

Mounting bracket for rear wall mounting

### OMH-RL28-C


Weld slag cover model

#### OMH-K01

dove tail mounting clamp

Approvals and certificates	
Protection class	II, rated voltage $\leq$ 250 V AC with pollution degree 1-2 according to IEC 60664-1
UL approval	cULus Listed, Class 2 Power Source, Type 1 enclosure
CCC approval	CCC approval / marking not required for products rated ≤36 V

# **Curves/Diagrams**



# **Preferences**

#### Teach-In:

You can use the rotary switch to select the output Q1 or Q2 and the relevant switching threshold A or B for teaching in.

The yellow LEDs indicate the current state of the selected output.


To store a switching threshold (distance measured value), press and hold the "SET" button until the yellow and green LEDs flash in phase (approx. 2 s). Teach-In starts when the "SET" button is released.

A successful Teach-In is indicated by rapidly alternating flashing (2.5 Hz) of the yellow and green LEDs.

An unsuccessful Teach-In is indicated by alternating flashing (8 Hz) of the yellow and green LEDs.

After an unsuccessful Teach-In, the sensor continues to operate with the previous valid setting after the relevant visual fault signal is issued.

Different switching modes can be defined by teaching in the relevant distance measured values for the switching thresholds A and B:



Every taught-in switching threshold can be retaught (overwritten) by pressing the SET button again.

Pressing and holding the "SET" button for > 5 s completely deletes the taught-in value. The yellow and green LEDs go out simultaneously to indicate that this procedure has been completed.

### Default setting:

In general, no switching points are set at the factory. The outputs are switched to low.

#### Reset to default settings:

- Set the rotary switch to the "RUN" position
- Press and hold the "SET" button until the yellow and green LEDs stop flashing in phase (approx. 10 s)
- If the green LED lights up, the procedure is complete.

#### Error messages

- Short circuit: In the event of a short circuit at the sensor output, the green LED flashes with a frequency of approx. 4 Hz.
- Teach error:In the event of a teach error, the yellow and green LEDs flash alternately with a frequency of approx. 8 Hz.

219475\_eng.xml

# Note!

The difference in the taught-in distance measured values for the switching thresholds A and B must be greater than the switching hysteresis set in the sensor.

On delivery, the switching hysteresis is 15 mm.

If the difference in the taught-in measured values is the same as or smaller than the set switching hysteresis, the sensor will visually signal an unsuccessful Teach-In. The last distance measured value that was taught in will not be adopted by the sensor.

Select a new distance measured value for switching threshold A or B with a greater difference between the switching thresholds.

Teach in this distance measured value on the sensor again.

### Laser notice laser class 2

- The irradiation can lead to irritation especially in a dark environment. Do not point at people!
- · Caution: Do not look into the beam!
- Maintenance and repairs should only be carried out by authorized service personnel!
- Attach the device so that the warning is clearly visible and readable.
- Caution Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.