



(€





# **Model Number**

### OBG8000-R200-EP-IO-V3

Retroreflective sensor (glass) with 3-pin, M8 x 1 connector

### **Features**

- Medium design with versatile mounting options
- Detects transparent objects, i.e., clear glass, PET and transparent films
- Two machines in one: clear object detection or reflection operating mode with long range
- High degree of protection IP69K
- IO-link interface for service and process data

## **Product information**


The optical sensors in the series are the first devices to offer an end-to-end solution in a medium-sized standard design-from the thru-beam sensor through to the measuring distance sensor. As a result of this design, the sensors are able to perform practically all standard automation tasks.

The entire series enables sensors to communicate via IO-Link.

The DuraBeam laser sensors are durable and can be used in the same way as a standard

Multi Pixel Technology (MPT) ensures that the standard sensors are flexible and can be adapted to the application environment.

# **Dimensions**



# **Electrical connection**




## **Pinout**

Wire colors in accordance with EN 60947-5-2



BU BK

# Indicators/operating means





1	Mode rotary switch	
2	Teach-in button	
3	Operating indicator/dark-on	GN
4	Function indicator	YE
5	Operating indicator/light-on	GN

N	Normal operation		
Ι	10 % contrast detection		
Ш	18 % contrast detection		
Ш	40 % contrast detection		
L/D	Switching type		
0	Keylock		

Technical data		
General specifications		
Effective detection range		0 5.6 m in TEACH mode; 0 8 m at switch position "N"
Reflector distance		0 5.6 m in TEACH mode; 0 8 m at switch position "N'
Threshold detection range		9 m
Reference target		H85-2 reflector
Light source		LED
Light type		modulated visible red light
LED risk group labelling		exempt group
Polarization filter		yes
Diameter of the light spot		approx. 170 mm at a distance of 3.5 m
Angle of divergence		approx. 5 °
Ambient light limit		EN 60947-5-2 : 18000 Lux
unctional safety related parar	meters	
MTTF <sub>d</sub>		600 a
Mission Time (T <sub>M</sub> )		20 a
Diagnostic Coverage (DC)		0 %
ndicators/operating means		
Operation indicator		LED green: constantly on - power on flashing (4Hz) - short circuit flashing with short break (1 Hz) - IO-Link mode
Function indicator		Yellow LED: Permanently lit - light path clear Permanently off - object detected Flashing (4 Hz) - insufficient operating reserve
Control elements		Teach-In key
Control elements		5-step rotary switch for operating modes selection
Contrast detection levels		10 % - clean, water filled PET bottles 18 % - clear glass bottles 40 % - colored glass or opaque materials Adjustable via rotary switch
lectrical specifications		
Operating voltage	$U_B$	10 30 V DC
Ripple		max. 10 %
No-load supply current	I <sub>0</sub>	< 25 mA at 24 V supply voltage
Protection class		III
nterface		
Interface type		IO-Link (via C/Q = pin 4)
Device profile		Identification and diagnosis Smart Sensor type 2.4
Transfer rate		COM 2 (38.4 kBaud)
IO-Link Revision		1.1
Min. cycle time		2.3 ms
Process data witdh		Process data input 2 Bit Process data output 2 Bit
SIO mode support		yes
Device ID		0x111A01 (1120769)
Compatible master port type		A
Output		
Switching type		The switching type of the sensor is adjustable. The default setting is: C/Q - Pin4: NPN normally open / dark-on, PNP normally closlight-on, IO-Link
Signal output		1 push-pull (4 in 1) output, short-circuit protected, reverse polarity protected, overvoltage protected
Switching voltage		max. 30 V DC
Switching current		max. 100 mA , resistive load
Usage category		DC-12 and DC-13
Voltage drop	$U_d$	≤ 1.5 V DC
Switching frequency	f	500 Hz
Response time		1 ms
conformity		
Communication interface		IEC 61131-9
Product standard		EN 60947-5-2
mbient conditions		·· ·
Ambient temperature		-20 60 °C (-4 140 °F)
Storage temperature		-40 70 °C (-40 158 °F)
Mechanical specifications		
Housing width		15 mm
Housing width Housing height		50.6 mm
Housing depth		41.7 mm
riousing acpui		11.7 mm IP67 / IP69 / IP69K
Degree of protection		
Degree of protection Connection		Connector plug, M8 x 1, 3 pin, rotatable by 90°

# Accessories

# V3-GM-2M-PUR

Female cordset single-ended, M8, 3-pin, PUR cable

### V3-WM-2M-PUR

Female cordset single-ended, M8, 3-pin, PUR cable

### IO-Link-Master02-USB

IO-Link master, supply via USB port or separate power supply, LED indicators, M12 plug for sensor connection

### REF-H85-2

Reflector, rectangular 84.5 mm x 84.5 mm, mounting holes

### REF-C110-2

Reflector, round ø 84 mm, central mounting hole

Reflector, round ø 80.87 mm, central mounting hole

Reflector, rectangular 60 mm x 19 mm, mounting holes

### OFR-100/100

Reflective tape 100 mm x 100 mm

REF-H32G-2

### REF-ORR50G-2

# OMH-MLV12-HWK

Mounting bracket for series MLV12 sensors

# OMH-R200-01

Mounting aid for round steel ø 12 mm or sheet 1.5 mm ... 3 mm


# **OMH-R20x-Quick-Mount**


Quick mounting accessory

## **OMH-MLV12-HWG**

Mounting bracket for series MLV12 sensors

# **Curves/Diagrams**





# **Settings**

### Teach-in:

295670-100142\_eng.xml

issue: 2019-10-31

Date of

date:

Release

Use the rotary switch to select the required operating mode: Normal mode (N) or contrast level I – III.

To teach in a threshold or activate an operating mode, press the "TI" button until the yellow and green LEDs flash in phase (approx. 1 s).

Release the "TI" button. Teach-in starts.

Successful teach-in is indicated by alternating flashing (2.5 Hz) of the yellow and green LEDs. The sensor will now operate in the selected operating mode with the taught-in threshold.

An unsuccessful teach-in is indicated by rapidly alternating flashing (8 Hz) of the yellow and green LEDs. After an unsuccessful teach-in, the sensor continues to operate with the previous valid setting after the relevant visual fault signal is issued.

 $\label{thm:condition} \mbox{Every taught-in switching threshold can be re-taught (overwritten) by pressing the "TI" button again.}$ 

Note: To ensure that the device functions reliably in Contrast mode, the device must be powered on at least 30 s before Teach-in.

Setting the Device to Maximum Sensitivity

Use the rotary switch to select the Normal mode (N) position.

Press the "TI" button for > 4 s. The yellow and green LEDs will go out.

Release the "TI" button.

The settings will be reset to maximum sensitivity. After successfully resetting, the yellow and green LEDs will flash alternately (2.5 Hz).

Switching between light on/dark on

Use the rotary switch to select the light on/dark on (L/D) position.

Press the "TI" button for > 1 s.

The respective operating indicator LED (L/D) will illuminate green and the switching type will change.

₱ PEPPERL+FUCHS

To reset the switching type, press the "TI" button for > 4 s.

The respective operating indicator LED (L/D) will illuminate green and the operating indicator will be reset to the most recently active switching

# **Reset to Default Settings**

Use the rotary switch to select the O position.

Press the "TI" button for  $> 10 \ s$ . The yellow and the green LEDs will both switch off.

Release the "TI" button. The yellow LED is on.

After resetting, the sensor will operate with the following default settings:

- Normal mode (N)
- · Maximum sensitivity adjustment
- · Dark on
- Pin 2 (white core): antivalent switching output

**FPEPPERL+FUCHS**